

**February 4, 2019**

**ADDENDUM #2**

**19-002 Veterans Tribute Park Memorial**

Addendum #2 is being issued to clarify questions asked at the Pre-Bid Meeting held January 24, 2019 at 10:00 am.

See attached.

---

Bidders shall sign this Addendum as acknowledgment and return it with the bid.

**BID ADDENDUM #2  
Bid 19-002**

**Addendum #2**

**Dated February 4, 2019**

We, the undersigned, acknowledge the receipt of the above addendum, as dated.

By: \_\_\_\_\_

Title: \_\_\_\_\_

Company: \_\_\_\_\_

Date: \_\_\_\_\_

19-002 Veterans Tribute Memorial							
RFI #	Date Rcvd	Date of Response	Company	Contact	Answered by	Question	Answer
1	1/21/2019	1/22/2019	Meyer Electric	Ralph Smith	SWT	Sheet E-101, Keyed Note 9- Who is to provide and install the Hydrodynamics vault and electrical panel board?	GC/ Subcontractor to provide Hydrodynamic vault and electrical panel board.
2	1/21/2019	1/22/2019	Meyer Electric	Ralph Smith	SWT	Sheet E-101 Keyed Note 10- Where is this (Wiremold Ground Box) shown to be installed on the plans other than E-101 and who is to provide this	Wire ground box to be installed within memorial overlook plaza, SWT can provide exact location.
3	1/21/2019	1/24/2019	Meyer Electric	Ralph Smith	St Charles County/ SWT	<p>Please clarify what type of lighting you are expecting for the Uplighting of the Trees in Addendum No 5. Do you want an inground light, which is installed underground with a lens at the surface and the voltage reduced to 12 Volts at each light with conduit and wire installed from the Vault to each light. The cost for this type of light fixture alone, not counting conduit, wire or installation will be between \$500 &amp; \$700 each. The second choice is run Low Voltage Cable from the Vault to each light which will be mounted to a Stake driven in the ground with the Uplight attached. The cost for this type of light is between \$100 to \$200 each. Please advise your thoughts to the above as you can see I do not know what you are expecting and with the difference in cost of the fixtures I do not know how to bid this Item.</p>	<p>The County prefers that the lighting be a low voltage lighting, with conduit sleeves installed under sidewalks and direct burial siemese cable sized for the length of run. A fixture the County prefers is BK Uplight -Denali series floodlight Delta Star - LED x61 2700 CCT optics, FL, DS, medium flood, black wrinkle finish, shielding: honeycomb baffle.</p>

4	1/28/2019	1/28/2019	Ideal Landscapes	Rebecca White	St. Charles County/ SWT	Per addendum #1 clarification was provided on what species of trees were to be included with alternate #3 however can you please provide clarification of quantity needed for these (4) species of trees?	The trees listed on Addendum 1 for alternate 3 are the four tree species that shall be bid for a 6" caliper. The sweetgum had been removed from the plans. The quantity shall be as follows in the plant schedule.
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							