



## Addendum D

Project Name: **LINCOLN COUNTY FIRE PROTECTION DISTRICT,  
HOUSE NO. 2 BUILDING**

Project Number: **20-1521.00**

Date Issued: **January 4, 2021**

### General notes;

1. Addendum D finalizes questions unanswered from Addendum C
2. In reference to article 11 of the contract for insurance and bonds, the following changes will be made and can be figured for bidding and can assume will be incorporated into the GC contract upon award. The umbrella policy requirement will be changed to \$5,000,000 for General Contractors and \$2,000,000 for Subcontractors.

### Substitution Requests

1. N/A

### RFI's and Responses;

1. *Question: Sheet E001 in Addendum C has a clouded section devoted to the heated driveway alternate. The first line says "For the front Drive". Addendum B said 10' out on front and back. Can you confirm which?*  
Response: heated driveway to be 10' out front and 10' out back front the apparatus bay doors.
2. *Question: The hose reels called out on A102 KN #29 simply says "One mechanical rewind and one electrical rewind hose reel" P001 – HR1 is listed as provided by owner. There is no detail on HR-2.*  
Response: Both mechanical rewind and electrical rewind hose reels to be contractor furnished, contractor installed. BOD Hose Reel: Hannay Reels, Inc. Series 6000 model #6024-23-24. There is a mechanical and electrical rewind option for the same model.

### Specification Changes;

1. N/A

### The Sheets with Drawing Changes are as Follows;

3. N/A

END OF ADDENDUM D