

## Addendum

TO:	COMPANY:	FAX NO/EMAIL:
Jeremy Way	Wright City School District	636-745-7200
FROM:	ADDENDUM ISSUE DATE:	ADDENDUM NUMBER:
Bond Architects	11-9-2022	3
PROJECT:	PROJECT NO:	
Wright City New HS	20034	

### TO ALL BIDDERS:

THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL BID DOCUMENTS DATED 10-12-2022. PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM.

### General Questions

Bids for East elementary will be due at 2:00 pm and opened at 2:30 pm on 11-15-2022  
Bids for the New High School will be due at 3:00 pm and opened at 3:30 pm on 11-15-2022

1. Can you provide a section cut of the track rock base and asphalt profile for base bid work?
  - a. 8" aggregate gravel rock, 3" of asphalt.
2. Should the soil remediation for Alternate No. 2 Performance Gym be carried under the Base Bid or Alternate No. 2 pricing?
  - a. Base bid.
3. Thinking our base bid will reflect 12" of soil remediation under base bid drives, parking and gravel road/parking. We will carry the 12" soil remediation 5' inside future pavement, and leave future pavement (or soil) at finish grade versus subgrade to avoid ponding; please confirm.
  - a. Leave the future pavement at finish grade.
4. Should the sanitary laterals for Alternates No. 2 & No. 3 be carried under the Base Bid or included in the Alternates pricing?
  - a. Base bid.

### CHANGES TO THE PROJECT MANUAL

None

### CHANGES TO THE DRAWINGS

None

### LIST OF ATTACHMENTS

None

END OF ADDENDUM NO. 3